

NEW LEAF PREP ACADEMY
 360 AMS CT
 GREEN BAY, WI 54313

Project Number: 25002642
 Report Date: 1/21/2025
 Sampled By:

Samples: 5

Sample Number: 55006106
 Sample ID: Kitchen Sink
 Sample Date: 1/16/2025
 Date Received: 1/16/2025

Parameter	Results	Units	LOD	LOQ	Dil.	Method	Analyzed	Codes
<u>GENERAL ANALYSIS</u>								
TURBIDITY-LAB SCREENING	0.10	NTU	0.10	0.10	1	EPA180.1	01/17/25	
<u>METALS</u>								
LEAD, TOTAL	0.12	ug/L	0.04	0.13	1	EPA200.8	01/17/25	

Sample Number: 55006107
 Sample ID: Gym Bubbler
 Sample Date: 1/16/2025
 Date Received: 1/16/2025

Parameter	Results	Units	LOD	LOQ	Dil.	Method	Analyzed	Codes
<u>GENERAL ANALYSIS</u>								
TURBIDITY-LAB SCREENING	0.10	NTU	0.10	0.10	1	EPA180.1	01/17/25	
<u>METALS</u>								
LEAD, TOTAL	<0.04	ug/L	0.04	0.13	1	EPA200.8	01/17/25	

Sample Number: 55006108
 Sample ID: Art Room Sink
 Sample Date: 1/16/2025
 Date Received: 1/16/2025

Parameter	Results	Units	LOD	LOQ	Dil.	Method	Analyzed	Codes
<u>GENERAL ANALYSIS</u>								
TURBIDITY-LAB SCREENING	0.10	NTU	0.10	0.10	1	EPA180.1	01/17/25	
<u>METALS</u>								
LEAD, TOTAL	0.19	ug/L	0.04	0.13	1	EPA200.8	01/17/25	

Sample Number: 55006109
 Sample ID: Mens Restroom - South End (Right Sink)
 Sample Date: 1/16/2025
 Date Received: 1/16/2025

Parameter	Results	Units	LOD	LOQ	Dil.	Method	Analyzed	Codes
<u>GENERAL ANALYSIS</u>								
TURBIDITY-LAB SCREENING	0.10	NTU	0.10	0.10	1	EPA180.1	01/17/25	
<u>METALS</u>								
LEAD, TOTAL	0.22	ug/L	0.04	0.13	1	EPA200.8	01/17/25	

CERTIFICATIONS

Sample Number: 55006110
Sample ID: Hallway Bubbler – North End
Sample Date: 1/16/2025
Date Received: 1/16/2025

Parameter	Results	Units	LOD	LOQ	Dil.	Method	Analyzed	Codes
<u>GENERAL ANALYSIS</u>								
TURBIDITY-LAB SCREENING	0.10	NTU	0.10	0.10	1	EPA180.1	01/17/25	
<u>METALS</u>								
LEAD, TOTAL	<0.04	ug/L	0.04	0.13	1	EPA200.8	01/17/25	

The above results **MEET** these standards:

U.S. EPA National Primary Drinking Water Standard for Lead is 15 ug/l.

Turbidity tests the cloudiness of the water, and it is a requirement that we check it prior to analyzing metals. There is no EPA limit. If the result is over 1.0 NTU then we must process the sample with an acid digestion.

All LOD/LOQs adjusted for dilution and/or solids content.

LOD = Limit of Detection LOQ = Limit of Quantitation

BADGER LABORATORIES, INC.
WDNR Certified Lab #445023150
Approved By:



BL: dg